

Declaration of Performance
According to Construction Product Regulation EU No.305/2011

1. Unique identification code of the product:

Signaline FT-68

2. Type, batch or serial number or any other element allowing identification of the product as required under Article 11(4) of the CPR:

Signaline FT-68 + Cable reel numbers

3. Intended use or uses of the construction product:

Heat actuated device for special applications
Heat automatic fire detector

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under article 11(5) :

'Signaline' is the registered trade mark of:
LGM Products Ltd.
Unit 15 Riverside Park
Farnham
Surrey GU9 7UG
United Kingdom

5. Name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

LGM Products Ltd.
Unit 15 Riverside Park
Farnham
Surrey GU9 7UG
United Kingdom

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

System 2+

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

No applicable harmonized standard. The product identified in point 1 above has been manufactured , tested and inspected to conform in all respects to UL File S24913, Standard UL521

8. Declared performance:

Maxium ambient temperature 45°C
Alarm Temperature 68°

9. The performance of the product identified in point 1 and 2 is in conformity with the declared performance in point 8.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4

Signed for and on behalf of the manufacturer by:



Signature:

Name & function: **Alister Mogford, Director**

Date and place of issue:

24 February 2015 Farnham, Surrey UK

**Declaration of Performance
According to Construction Product Regulation EU No.305/2011**

1. Unique identification code of the product:

Signaline FT-68-R

2. Type, batch or serial number or any other element allowing identification of the product as required under Article 11(4) of the CPR:

Signaline FT-68-R + Cable reel numbers

3. Intended use or uses of the construction product:

**Heat actuated device for special applications
Heat automatic fire detector**

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under article 11(5) :

**'Signaline' is the registered trade mark of:
LGM Products Ltd.
Unit 15 Riverside Park
Farnham
Surrey GU9 7UG
United Kingdom**

5. Name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

**LGM Products Ltd.
Unit 15 Riverside Park
Farnham
Surrey GU9 7UG
United Kingdom**

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

System 2+

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

No applicable harmonized standard. The product identified in point 1 above has been manufactured , tested and inspected to conform in all respects to UL File S24913, Standard UL521

8. Declared performance:

**Maxium ambient temperature 45°C
Alarm Temperature 68°**

9. The performance of the product identified in point 1 and 2 is in conformity with the declared performance in point 8.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4

Signed for and on behalf of the manufacturer by:



Signature:

Name & function: **Alister Mogford, Director**

Date and place of issue:

24 February 2015 Farnham, Surrey UK

**Declaration of Performance
According to Construction Product Regulation EU No.305/2011**

1. Unique identification code of the product:

Signaline FT-88

2. Type, batch or serial number or any other element allowing identification of the product as required under Article 11(4) of the CPR:

Signaline FT-88 + Cable reel numbers

3. Intended use or uses of the construction product:

**Heat actuated device for special applications
Heat automatic fire detector**

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under article 11(5) :

**'Signaline' is the registered trade mark of:
LGM Products Ltd.
Unit 15 Riverside Park
Farnham
Surrey GU9 7UG
United Kingdom**

5. Name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

**LGM Products Ltd.
Unit 15 Riverside Park
Farnham
Surrey GU9 7UG
United Kingdom**

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

System 2+

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

No applicable harmonized standard. The product identified in point 1 above has been manufactured , tested and inspected to conform in all respects to UL File S24913, Standard UL521

8. Declared performance:

**Maxium ambient temperature 70°C
Alarm Temperature 88°**

9. The performance of the product identified in point 1 and 2 is in conformity with the declared performance in point 8.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4

Signed for and on behalf of the manufacturer by:



Signature:

Name & function: **Alister Mogford, Director**

Date and place of issue:

24 February 2015 Farnham, Surrey UK

**Declaration of Performance
According to Construction Product Regulation EU No.305/2011**

1. Unique identification code of the product:

Signaline FT-105

2. Type, batch or serial number or any other element allowing identification of the product as required under Article 11(4) of the CPR:

Signaline FT-105 + Cable reel numbers

3. Intended use or uses of the construction product:

**Heat actuated device for special applications
Heat automatic fire detector**

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under article 11(5) :

**'Signaline' is the registered trade mark of:
LGM Products Ltd.
Unit 15 Riverside Park
Farnham
Surrey GU9 7UG
United Kingdom**

5. Name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

**LGM Products Ltd.
Unit 15 Riverside Park
Farnham
Surrey GU9 7UG
United Kingdom**

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

System 2+

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

No applicable harmonized standard. The product identified in point 1 above has been manufactured , tested and inspected to conform in all respects to UL File S24913, Standard UL521

8. Declared performance:

**Maxium ambient temperature 85°C
Alarm Temperature 105°**

9. The performance of the product identified in point 1 and 2 is in conformity with the declared performance in point 8.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4

Signed for and on behalf of the manufacturer by:



Signature:

Name & function: **Alister Mogford, Director**

Date and place of issue:

24 February 2015 Farnham, Surrey UK

**Declaration of Performance
According to Construction Product Regulation EU No.305/2011**

1. Unique identification code of the product:

Signaline FT-105-R

2. Type, batch or serial number or any other element allowing identification of the product as required under Article 11(4) of the CPR:

Signaline FT-105-R + Cable reel numbers

3. Intended use or uses of the construction product:

**Heat actuated device for special applications
Heat automatic fire detector**

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under article 11(5) :

**'Signaline' is the registered trade mark of:
LGM Products Ltd.
Unit 15 Riverside Park
Farnham
Surrey GU9 7UG
United Kingdom**

5. Name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

**LGM Products Ltd.
Unit 15 Riverside Park
Farnham
Surrey GU9 7UG
United Kingdom**

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

System 2+

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

No applicable harmonized standard. The product identified in point 1 above has been manufactured , tested and inspected to conform in all respects to UL File S24913, Standard UL521

8. Declared performance:

**Maxium ambient temperature 85°C
Alarm Temperature 105°**

9. The performance of the product identified in point 1 and 2 is in conformity with the declared performance in point 8.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4

Signed for and on behalf of the manufacturer by:



Signature:

Name & function: **Alister Mogford, Director**

Date and place of issue:

24 February 2015 Farnham, Surrey UK

Declaration of Performance
According to Construction Product Regulation EU No.305/2011

1. Unique identification code of the product:

Signaline FT-185-R

2. Type, batch or serial number or any other element allowing identification of the product as required under Article 11(4) of the CPR:

Signaline FT-185-R + Cable reel numbers

3. Intended use or uses of the construction product:

Heat actuated device for special applications
Heat automatic fire detector

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under article 11(5) :

'Signaline' is the registered trade mark of:
LGM Products Ltd.
Unit 15 Riverside Park
Farnham
Surrey GU9 7UG
United Kingdom

5. Name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

LGM Products Ltd.
Unit 15 Riverside Park
Farnham
Surrey GU9 7UG
United Kingdom

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

System 2+

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

No applicable harmonized standard. The product identified in point 1 above has been manufactured , tested and inspected to conform in all respects to UL File S24913, Standard UL521

8. Declared performance:

Maxium ambient temperature 125°C
Alarm Temperature 185°

9. The performance of the product identified in point 1 and 2 is in conformity with the declared performance in point 8.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4

Signed for and on behalf of the manufacturer by:



Signature:

Name & function: **Alister Mogford, Director**

Date and place of issue:

24 February 2015 Farnham, Surrey UK